

California Regional Water Quality Control Board  
San Diego Region

**ADDENDUM NO. 1**  
**CLEANUP AND ABATEMENT ORDER NO. 98-28**  
for  
**CITY OF SAN DIEGO**  
**SAN DIEGO COUNTY**

The California Regional Water Quality Control Board, San Diego Region (hereinafter Regional Board), finds that:

1. By letter dated April 30, 1998 the City of San Diego submitted a technical assessment of the causes of the sewer overflows which occurred in February 1998 between Manholes # 54 through #58 in the vicinity of Rose Canyon and I-805 as required by Order No. 98-28.
2. The City of San Diego proposed measures and a time schedule for completing those measures that will abate the threatened violations of Order No. 96-04, *General Waste Discharge Requirements Prohibiting Sanitary Sewer Overflows by Sewage Collection Systems*.
3. This enforcement action is being taken for the protection of the environment and, as such is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, Section 21000 et seq.) in accordance with Section 15108, Chapter 3, Title 14, California Administrative Code.

**IT IS HEREBY ORDERED** that, pursuant to Section 13304 of Division 7 of the California Water Code, the City of San Diego shall comply with the following:

1. Complete project design for Miramar Trunk Sewer (MTS) Rehabilitation project to address inflow and infiltration along the sewer main alignment including the manholes by June 2, 1998.
2. Complete project design for MTS Relief Line by June 2, 1998. This will consist of a sewer main parallel to the existing trunk sewer, allowing for additional capacity in the most restricted area.
3. Include as part of the monthly status reports the Navy's progress in identifying Inflow and Infiltration as well as the status of the MTS Rehabilitation project and the MTS Relief Line.
4. Complete construction for MTS Rehabilitation project by November 24, 1998.
5. Complete construction for MTS Relief Line by November 24, 1998.

6. The November 1998 monthly status report shall include a certification statement that construction has been completed for the MTS Rehabilitation project and the MTS Relief Line.

*Pursuant to California Water Code Section 13350, any person who intentionally or negligently violates a cleanup and abatement order may be liable civilly in an amount which shall not exceed five thousand dollars (\$5,000), but shall not be less than (\$500), for each day in which the cleanup and abatement order is violated.*

---

JOHN H. ROBERTUS  
Executive Officer

Date issued: March 30, 2001

JHR:erd:rwm  
file: c:\mydocs\wpwin\cao#9828.ad1